

HTP, Inc • 272 Duchaine Blvd, New Bedford, MA 02745 • www.htproducts.com

## Mod Con VWH Commercial Condensing Hot Water Supply Boiler Submittal

| mod don vvii doninicidiai donaciisi   | ing flot trater ouppry Boiler oublinitial   |
|---|---|
| JOB NAME:   |   |
| LOCATION:   |   |
| ARCH./ENGR.:  |   |
| WHOLESALER:   |   |
| MECH. CONTRACTOR:   |   |
| MODEL NUMBER:   |   |
| TYPE OF GAS:  |   |
| BTU/HR INPUT LOW - HIGH FIRE:   |   |
| NOTES:  |   |
| <ul> <li>Heat Exchanger</li> <li>All Stainless Steel Construction. 160 PSI ASME stamped construction. National Board listed.</li> <li>Gasketless heat exchanger design</li> <li>ASME 150 PSI relief valve</li> <li>Front service access to combustion chamber and burner</li> <li>Inlet and outlet temperature sensor</li> </ul> Combustion System <ul> <li>Modulating burner with up to 5 to 1 turndown</li> <li>Up to 98% thermal efficiency</li> <li>High-Grade Inconel burner design</li> <li>Spark ignition</li> <li>Models available for Natural or LP Gas</li> <li>Dual flame monitoring (Spark and Flame probe)</li> <li>Gas Valve pressure range 3 ½" minimum to 14" maximum Water Column</li> </ul> | Additional Features  Superior condensate collection system with float switch A/C convenience receptacle for condensate pump Syear limited warranty Vents in PVC - CPVC - stainless steel – up to 200 equivalent feet (combined intake and exhaust) Optional stacking kit double stacks boilers for space savings Flow Switch Built-in low water cut-off Field wiring connection board / Cascade wiring CAT 3 or 5 Adjustable leveling legs Flue / Water high temperature limit with Manual reset Dry contact for alarm output Blocked vent pressure switch Pressure and temperature gauge System / Pipe sensor – one (1) supplied with unit |
| <ul> <li>926 Digital operating control with LED display</li> <li>LED indicators for System Pump – Boiler Pump – DHW Pump – System Fault – System Operation – Freeze Protection – Flame On – Fault Indication</li> <li>On/Off Switch</li> <li>Password protected</li> <li>Multiple 120 volt pump outputs – boiler pump – system pump - DHW pump</li> <li>24 volt monitoring</li> <li>0-10 VDC input from a building management system</li> <li>Boiler output regulation (adjustment of boiler output down to 50% of rated capacity)</li> <li>Cascade up to 8 boilers</li> </ul>  | <ul> <li>☐ Indirect Sensor (Part # 7250P-325)</li> <li>☐ Additional System Sensor (Part # 7250P-324)</li> <li>☐ 4" Stainless Steel Outside Termination Vent Kit (Part # V2000)</li> <li>☐ 6" Stainless Steel Outside Termination Vent Kit (Part # V3000)</li> <li>☐ High and Low Gas Pressure Switch Kit with Manual Reset (Part # 7350P-600)</li> <li>☐ U.L. 353 Compliant Low Water Cut-Off Interface Kit w/ Manual Reset (Part # 7450P-225)</li> <li>☐ Alarm System to monitor any failure (Part # 7350P-602)</li> </ul>   |
|   | Condensate Neutralizer (Part # 7350P-611)   |

☐ Boiler Stacking Kit (Part # 7350P-603)

☐ Boiler Caster Kit (Part # 7350P-604)

PC Connection Cable w / Software (Part # 7350P-320)

LP-280.sub Rev. 5.30.17

